

DECLARATION OF PERFORMANCE

No. 20180423-RGP / Rev.A

**1. ID code of the product-type:***RGP multi cable transit system***2. Intended use:***Fire stopping modular cable penetration sealing system***3. Manufacturer:***MCT Brattberg AB**Lyckeåborg**37192 Karlskrona, Sweden***4. Authorised representative:***N/A***5. System acc. AVCP:***System 1***6 a. Harmonized standard:***N/A***6 b. European Assessment Document***EAD No. 350454-00-1104***European Technical Assessment***ETA-16/0474***Technical Assessment Body***TZÚS- Technical and Test Institute for Construction Prague***Notified body***1812***7. Declaration of performance:**


Features	Performance	Harmonized techn. Spec.
Reaction to fire	Class E	According to EN 13501-1
Resistance to fire	EI 120 & E 120	According to EN 13501-2
Durability and serviceability	Use category X for the system with components made of stainless steel or galvanized mild steel. Use category Z ₂ for the system with components made of coated mild steel or aluminium.	

The performance of the product identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Regulation (EU) No 305/2011, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of MCT Brattberg AB



Technical Engineer
Johan Fagerberg



Quality Manager
Magnus Larsen

Karlskrona 2018-04-20